

## Environmental Protection Agency

## § 408.157

under § 408.152(a) shall meet the following limitations:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
	Metric units (kg/kg of seafood)	
BOD <sub>5</sub> .....	3.5	2.8
TSS .....	2.6	1.7
Oil and grease .....	3.2	1.4
pH .....	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
BOD <sub>5</sub> .....	3.5	2.8
TSS .....	2.6	1.7
Oil and grease .....	3.2	1.4
pH .....	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55781, Dec. 1, 1975, as amended at 41 FR 31821, July 30, 1976; 60 FR 33943, June 29, 1995]

### § 408.153 [Reserved]

#### § 408.154 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
BOD <sub>5</sub> .....	No limitation.
TSS .....	Do.
pH .....	Do.
Oil and grease .....	Do.

[40 FR 55781, Dec. 1, 1975, as amended at 60 FR 33943, June 29, 1995]

#### § 408.155 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may

be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
	Metric units (kilograms per 1,000 kg of seafood)	
BOD <sub>5</sub> .....	6.7	3.8
TSS .....	3.7	1.5
Oil and grease .....	1.4	0.76
pH .....	( <sup>1</sup> )	( <sup>1</sup> )
	English units (pounds per 1,000 lb of seafood)	
BOD <sub>5</sub> .....	6.7	3.8
TSS .....	3.7	1.5
Oil and grease .....	1.4	0.76
pH .....	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55781, Dec. 1, 1975, as amended at 41 FR 31821, July 30, 1976]

#### § 408.156 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
BOD <sub>5</sub> .....	No limitation.
TSS .....	Do.
pH .....	Do.
Oil and grease .....	Do.

[40 FR 55781, Dec. 1, 1975, as amended at 60 FR 33944, June 29, 1995]

#### § 408.157 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall